



SWR Institute
400 Admiral Blvd
Kansas City, MO 64106
816.472.7974
info@swrionline.org

Product Name: DOWSIL 790 Silicone Building Sealant

Submitted by: Dow Silicones Corporation
PO Box 994
Midland, MI 48686-0994
ckaiser3@dow.com
dow.com/construction

Test Results

ASTM C719 Adhesion and Cohesion of Elastomeric Joint Sealants
Under Cyclic Movement [Hockman Cycle];
Pass: Yes Extension: +100% Compression: -50%
Substrate: Mortar, Glass, and Aluminum Substrates, Aluminum substrate was primed with
Dowsil 1200-OS Primer.

Validation Date: 8/26/2024

Expiration Date: 8/25/2029

Lab Details: Intertek
130 Derry Court
York, Pennsylvania 17406
Phone: 717.764.7700