

SWR Institute 400 Admiral Blvd Kansas City, MO 64106 816.472.7974 info@swrionline.org

Product Name: DOWSIL Contractors Weatherproofing Sealant (CWS)

Submitted by: Dow Silicones Corporation

2200 W. Salzburg Road Midland, MI 48686 <u>k.allore@dow.com</u> dow.com/construction

Test Results

ASTM C 719 Adhesion and Cohesion of Elastomeric Joint Sealants Under Cyclic Movement [Hockman Cycle]; Pass:

Yes Extension: +35% Compression: -35% Substrate: Primed mortar, glass and aluminum. [Mortar

substrate was primed with DOWSIL Construction Primer P]

Validation Date: 1/26/2020

Expiration Date: 1/25/2026

Lab Details: Architectural Testing

130 Derry Court York, PA 17406 Phone: 717.764.7700 Fax: 717.764.4129