



SWR Institute
400 Admiral Blvd
Kansas City, MO 64106
816.472.7974
info@swrionline.org

Product Name: DOWSIL™ Silicone Transition Strip

Submitted by: Dow Silicones Corporation
2200 W. Salzburg Rd.
Midland, MI 48686
ahlinka@dow.com
dow.com/construction

Test Results

ASTM C 1523-10 Standard Test Method for Determining Modulus, Tear and Adhesion Properties of Pre-cured Elastomeric Joint Sealants Movement, Cohesion & adhesion - 200% Dry/Room Temperature Loss of Adhesion/Cohesion - None (Pass) Water Immersion Loss of Adhesion/Cohesion - None (Pass) Frozen Loss of Adhesion/Cohesion - None (Pass) Heat Loss of Adhesion/Cohesion - None (Pass) Artificial Weathering Loss of Adhesion/Cohesion - None (Pass) Tear Propagation - T-Tear

ASTM D 412 Vulcanized Rubber and Thermoplastic Elastomers - Tension Ultimate Elongation Results - 435%

PRI Construction
Materials Technologies
LLC

Validation Date: 6/3/2024

Expiration Date: 6/2/2029

Lab Details: PRI Construction Materials Technologies LLC
6412 Badger Drive
Tampa, FL 33647
Phone: 813.621.5777