



SWR Institute
400 Admiral Blvd
Kansas City, MO 64106
816.472.7974
info@swrionline.org

Product Name: DOWSIL™ 756 SM Building Sealant

Submitted by: Dow Silicones Corporation
2200 W. Salzburg Rd
Midland, MI 48686-0994
k.allore@dow.com
dow.com/construction

Test Results

ASTM C719 Adhesion and Cohesion of Elastomeric Joint Sealants Under Cyclic Movement [Hockman Cycle]; Pass:
Yes Extension: +50% Compression: -50% Substrate: Unprimed Anodized Aluminum, Unprimed Glass,
Mortar [Primed with DOWSIL™ Construction Primer P], and Kynar [Primed with DOWSIL™ Primer-C
OS]

Validation Date: 9/20/2023

Expiration Date: 9/19/2028

Lab Details: Intertek
130 Derry Court
York, PA 17406
Phone: 717.764.7700
Fax: 717-764-4129