



SWR Institute
400 Admiral Blvd
Kansas City, MO 64106
816.472.7974
info@swrionline.org

Product Name: DOWSIL 756 SMS Silicone Building Sealant

Submitted by: Dow Silicones Corporation
2200 W. Salzburg Rd
Midland, MI 48686-0994
k.allore@dowcorning.com
www.dowcorning.com

Test Results

ASTM C719 Adhesion and Cohesion of Elastomeric Joint Sealants Under Cyclic Movement [Hockman Cycle]; Pass: Yes Extension: +50% Compression: -50% Substrate: Aluminum, Glass, Mortar and Duranar [Dow Primer 1200OS Primer, and Concrete primed with Primer P was applied to mortar substrates]

Validation Date: 3/31/2017

Expiration Date: 3/30/2022

Lab Details: PRI Construction Material Technologies
6408 Badger Drive
Tampa, FL 33610
Phone: 813.621.5777
Fax: 813.621.5840