



SWR Institute  
400 Admiral Blvd  
Kansas City, MO 64106  
816.472.7974  
[info@swrionline.org](mailto:info@swrionline.org)

---

Product Name: DOWSIL 758 Silicone Weather Barrier Sealant

Submitted by: Dow Silicones Corporation  
2200 W. Salzburg Rd.  
Midland , MI 48686  
[k.allore@dowcorning.com](mailto:k.allore@dowcorning.com)  
[www.dowcorning.com](http://www.dowcorning.com)

#### Test Results

*ASTM C719* Adhesion and Cohesion of Elastomeric Joint Sealants Under Cyclic Movement [Hockman Cycle]; Pass: Yes Extension: +25% Compression: -25% Substrate: Unprimed Aluminum and Glass and Primed Concrete substrates [Dow Corning Primer P was Applied to concrete substrate].

Validation Date: 1/25/2016

Expiration Date: 1/24/2021

Lab Details: Architectural Testing  
130 Derry Court  
York, PA 17406-8405  
Phone: 717-764-7700  
Fax: 717-764-4129