



SWR Institute  
400 Admiral Blvd  
Kansas City, MO 64106  
816.472.7974  
[info@swronline.org](mailto:info@swronline.org)

---

Product Name: DOWSIL 790 Silicone Building Sealant

Submitted by: Dow Silicones Corporation  
PO Box 994  
Midland, MI 48686-0994  
[k.allore@dowcorning.com](mailto:k.allore@dowcorning.com)  
[www.dowcorning.com](http://www.dowcorning.com)

#### Test Results

*ASTM C719* Adhesion and Cohesion of Elastomeric Joint Sealants  
Under Cyclic Movement [Hockman Cycle];  
Pass: Yes Extension: +100% Compression: -50%  
Substrate: Mortar, Aluminum, Glass [Dow Corning 1200 OS Primer was Applied to aluminum substrate]

Validation Date: 9/19/2016

Expiration Date: 9/18/2021

Lab Details: Architectural Testing  
130 Derry Court  
York, PA 17406-8405  
Phone: 717.764.7700  
Fax: 717.764.4129