



SWR Institute
400 Admiral Blvd
Kansas City, MO 64106
816.472.7974
info@swrionline.org

Product Name: DOWSIL 995 Silicone Structural Glazing Sealant

Submitted by: Dow Silicones Corporation
2200 W. Salzburg Rd.
Midland, MI 48686
k.allore@dow.com
<https://consumer.dow.com>

Test Results

ASTM C 719 Adhesion and Cohesion of Elastomeric Joint Sealants Under Cyclic Movement [Hockman Cycle];
Pass: Yes
Extension: +50% Compression: -50% Substrate: Glass, aluminum and Duranar [All unprimed]

Validation Date: 4/19/2019

Expiration Date: 4/18/2024

Lab Details: PRI Construction Materials
6408 Badger Drive
Tampa, FL 33610
Phone: 813.621.5777
Fax: 813.621.5840