



SWR Institute  
400 Admiral Blvd  
Kansas City, MO 64106  
816.472.7974  
[info@swrionline.org](mailto:info@swrionline.org)

---

Product Name: DOWSIL Contractors Weatherproofing Sealant

Submitted by: Dow Silicones Corporation  
2200 W. Salzburg Road  
Midland, MI 48686  
[k.allore@dowcorning.com](mailto:k.allore@dowcorning.com)  
[www.dowcorning.com](http://www.dowcorning.com)

#### Test Results

*ASTM C 719* Adhesion and Cohesion of Elastomeric Joint Sealants Under Cyclic Movement [Hockman Cycle]; Pass: Yes Extension: +25% Compression: -25% Substrate: Primed mortar, glass and aluminum. [Prime Coat Dow Corning Construction Primer P used on concrete substrates]

Validation Date: 9/20/2016

Expiration Date: 9/19/2021

Lab Details: Architectural Testing  
130 Derry Court  
York, PA 17406  
Phone: 717.764.7700  
Fax: 717.764.4129