



SWR Institute  
400 Admiral Blvd  
Kansas City, MO 64106  
816.472.7974  
[info@swrionline.org](mailto:info@swrionline.org)

---

Product Name: DOWSIL Contractors Concrete Sealant

Submitted by: Dow Silicones Corporation  
2200 W. Salzburg Rd.  
Midland, MI 48686  
[k.allore@dowcorning.com](mailto:k.allore@dowcorning.com)  
[www.dowcorning.com](http://www.dowcorning.com)

#### Test Results

*ASTM C 719* Adhesion and Cohesion of Elastomeric Joint Sealants Under Cyclic Movement [Hockman Cycle]; Pass: Yes Extension: +50% Compression: -50% Substrate: Unprimed mortar, glass; primed anodized aluminum. [1200 OS Primer was applied to anodized aluminum substrates.]

Validation Date: 4/17/2018

Expiration Date: 4/16/2023

Lab Details: PRI Construction Materials  
6408 Badger Drive  
Tampa, FL 33610  
Phone: 813.621.5777  
Fax: 813.621.5840